

March 11, 2025

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

**MIDLAND CSD
MS/HS BUILDING**

Test 2 March 3-6-2025

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11903264	B1 (SUPERINT) HAD A WEIRD TEST RESU	2025-03-03 @ 6:00 am	2025-03-06 @ 2:00 am	7.1 ± 0.7	2025-03-11
11903265	B2 (CARRIE)	2025-03-03 @ 6:00 am	2025-03-06 @ 2:00 am	7.2 ± 0.7	2025-03-11
11903266	B3 (LACIE)	2025-03-03 @ 6:00 am	2025-03-06 @ 2:00 am	6.7 ± 0.6	2025-03-11
11903267	B3-2 (LACIE) D	2025-03-03 @ 6:00 am	2025-03-06 @ 2:00 am	6.9 ± 0.6	2025-03-11
11903268	B4 (ME)	2025-03-03 @ 6:00 am	2025-03-06 @ 2:00 am	8.3 ± 0.7	2025-03-11
11903269	B5 (LUENSMAN)	2025-03-03 @ 6:00 am	2025-03-06 @ 2:00 am	6.4 ± 0.7	2025-03-11
11903263	BLANK	2025-03-03 @ 6:00 am	2025-03-06 @ 2:00 am	< 0.3	2025-03-11

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

Room	B1	B2	B3	B3-2	B4	B5	PE Office
3-3-2025 Test 2	7.1	7.2	6.7	6.9	8.3	6.4	N/A
2-10-2025 Test 1	N/A	5.0	6.8	N/A	9.3	4.8	4.6
Average	7.1	6.1	6.7	6.9	8.8	5.6	4.6